



**NOTE:**  
ANY SUBDRAIN UNDER THE SEWER SHALL BE REPLACED SUCH THAT NO FLOW SHALL ENTER THE WATER LINE TRENCH.



**SEWER CROSSING UNDER  
WITH "D" LESS THAN 2'**



**SECTION A-A**

**NOTE:**

ALL EXIST SEWER DAMAGED DURING INSTALLATION  
MUST BE REPLACED WITH PVC PIPE.

**DENVER WATER**

1600 West 12th Avenue • Denver, Colorado 80204  
Phone (303) 628-6000 • Telecopier No. (303) 628-6851

**CROSSING  
STORM AND SANITARY SEWERS**

Scale: NONE Date: JULY 1995

Drawn: C.B.B. Tr:      Ck:     

Approved: [Signature] Dr. 127 No. 35